

ENVIRONMENTAL LABWORKS, INC.

ELAP #10824

October 24, 2016

Mr. Barry Korol
P.O. Box 3205
Kingston, NY 12402

Dear Barry,

The following are results of the analyses performed on samples from **Woodstock Day School - 1430 Glasco Turnpike, Saugerties, NY** received at the laboratory on 10/05/16.

Date/Time Collected: 09/24/16 4:15-5:10pm First Draw
Collected By: B. Korol
Sample ID: 10051650
Secondary Lab ID: BK163546-55
PWS ID: 5530217

LOCATION	PARAMETER	RESULTS	ACTION LEVEL	METHOD
Green Bldg	Copper	0.38 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.004 mg/L	0.015 mg/L	EPA 200.8
Science Bldg	Copper	2.3 mg/L X	1.3 mg/L	EPA 200.8
	Lead	0.0067 mg/L	0.015 mg/L	EPA 200.8
Office Bldg	Copper	0.16 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.011 mg/L	0.015 mg/L	EPA 200.8
Main Bldg Classroom	Copper	0.32 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.006 mg/L	0.015 mg/L	EPA 200.8
Main Bldg Bathroom	Copper	0.39 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.0059 mg/L	0.015 mg/L	EPA 200.8
Ranch	Copper	0.37 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.021 mg/L X	0.015 mg/L	EPA 200.8
Red Bldg	Copper	0.66 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.011 mg/L	0.015 mg/L	EPA 200.8
Blue Bldg	Copper	0.29 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.0082 mg/L	0.015 mg/L	EPA 200.8
Grey Bldg Upstairs Bathroom	Copper	0.27 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.016 mg/L X	0.015 mg/L	EPA 200.8
Grey Bldg Downstairs Bathroom	Copper	0.42 mg/L	1.3 mg/L	EPA 200.8
	Lead	0.0028 mg/L	0.015 mg/L	EPA 200.8

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Woodstock Day School - 10051650

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

Trudie Lund for
Anthony J. Falco
Laboratory Director